

CAPPING FILL DRAINFIELD CHECKLIST



DEPARTMENT OF PLANNING AND DEVELOPMENT

210 S. W. 2nd ST
Newport, OR 97365
(541) 265-4192
Fax (541) 265-6945

Call for the following scheduled inspections. This checklist is only a guide and is not a complete list of DEQ regulations or county administrative rules regarding septic system installations. Inspections may be waived only with Sanitarian approval. Photographs of waived inspections will be required.

Inspection 1:

- _____A. Cap material is approved by agent for placement.
- _____B. Disposal area is scarified to a minimum of 10 feet from the edge of the lines to destroy vegetation
- _____C. Drain field is excavated to specified depth and bottom is level.

Inspection 2:

- _____A. Filter fabric placed over the lines
- _____B. Cap material is specified depth (10" over the drain media for an equal system and 16" over the drain media for a serial system to provide proper settled depth).
- _____C. There is good contact between the fill material and the native soil
- _____D. Landscaping or other erosion control measures are established

Note:

Capping fill drainfields may only be installed from June 1st to October 1st unless otherwise allowed by the sanitarian.